



MILBANK METERBASE  
NOTE: DO NOT BREAK NEUTRAL IN  
METERBASE.

NOTE 1

WEATHERPROOF DISCONNECT:  
MINIMUM OF (1) 120V GFCI  
PROTECTED RECEPTACLE

NOTE:

1. CENTER OF METERBASE MUST BE BETWEEN 5' AND 6'

## TEMPORARY SERVICE POLE MINIMUM 60 AMP SERVICE

SCALE: NOT TO SCALE	DATE: 10-11-2018	
DRAWN BY: AUSTIN CAPERTON		SHEET NO. 1

**LAWRENCEBURG UTILITY SYSTEMS**  
1607 N LOCUST AVENUE  
LAWRENCEBURG, TN 38464  
(931) 762-7161