



- ENGINEERING DEPARTMENT IS TO SPOT POLES
- WIRE TO BE DIRECT BURIAL
#6 USE, UF
- 9' POLE, 2' SET INTO GROUND
- CUSTOMER IS TO SUPPLY WIRE FROM METER TO TRANSFORMER
- MINIMUM OF 15' LEAD FROM POLE
- CUSTOMER IS TO SET POLE
- MUST BE INSPECTED BY STATE INSPECTOR BEFORE LUS WILL CONNECT
- TEMP SERVICE DOES NOT REQUIRE MILBANK METERBASE
- 3" CONDUIT TO HOUSE

SINGLE PH UG TRANSFORMER, UG TEMP SERVICE INSTALLATION GUIDE

SCALE: NOT TO SCALE

DATE: 12-16-2014

DRAWN BY: BRADY T. ALLRED

SHEET NO. 1

LAWRENCEBURG UTILITY SYSTEMS

1607 N LOCUST AVENUE
LAWRENCEBURG, TN 38464
(931) 762-7161