



MILBANK METERBASE
NOTE: DO NOT BREAK NEUTRAL IN
METERBASE.

NOTE 1

WEATHERPROOF DISCONNECT:
MINIMUM OF (1) 120V GFCI
PROTECTED RECEPTACLE

NOTE:
1. CENTER OF METERBASE MUST BE BETWEEN 5' AND 6'

TEMPORARY SERVICE POLE MINIMUM 60 AMP SERVICE

SCALE: NOT TO SCALE

DATE: 10-11-2018

DRAWN BY: JKJ

SHEET NO. 1

LAWRENCEBURG UTILITY SYSTEMS

1607 N LOCUST AVENUE
LAWRENCEBURG, TN 38464
(931) 762-7161